



PUDUCHERRY POWER CORPORATION LIMITED

(A GOVERNMENT OF PUDUCHERRY UNDERTAKING)

PROJECT OFFICE, T.R. PATTINAM 609 606, KARAİKAL.

Phone: 04368-233060, 233344

Email: ppclmmc@gmail.com

Telefax: 04368-233355.

Ref.No: AC-014/MMC/2025-26/ 506

GSTIN No.34AAACP6507E1ZS

Dt. 18/06.2025

ENQUIRY

To

Sub: Inviting offer for the supply of Diaphragm Pressure Gauges – Reg.,


QUOTATION TO BE:

Submitted on or before – 10.07.2025 – 5 PM	Opened on 11.07.2025 - 3.00 P M
Kept valid for 3 months from the date of opening	Submitted in ONE part.

Sealed quotations are invited for the supply of Diaphragm Pressure Gauges as per the Specification, data sheet enclosed and as per the terms and conditions mentioned therein.

Terms and conditions:

1. The rate quoted should be firm and inclusive of GST, freight and all other charges as admissible.
2. The materials should be original and specified make only.
3. The materials should be directly supplied to the PPCL site, T. R. Pattinam, Karaikal - 609 606, **on door delivery basis.**
4. **Payment: 100%** Payment will be made within **30 days** from the date of receipt of your invoice after receipt of materials in good condition. The **bill in triplicate** along with **Advance stamp fixed and signed receipt** should be sent to the undersigned for effecting payment.
5. The delivery period and mode of despatch should be clearly specified.
6. Any loss or damage during transit to site should be made good by the supplier free of charge provided the same is reported within 15 days of the arrival of material at site.
7. **Validity:** Your offer should be valid for **90** days from the date of tender opening.
8. Wax sealed quotations should be superscripted as “QUOTATION/ENQUIRY NO. AC-014 for the supply of Diaphragm pressure gauges”.
9. Quotations through fax /e-mail not accepted.
10. If the tender opening date happens to be a holiday, the tender will be opened on the next working day.
11. Our **GSTIN No.34AAACP6507E1ZS** is registered with Commercial Taxes Department, Puducherry. The GST number of the agency should be provided.
12. The undersigned reserves all rights to accept/reject any or all the quotations without assigning any reasons thereof.

 18/06/2025
EXECUTIVE ENGINEER (MECH)-PLANT



PUDUCHERRY POWER CORPORATION LIMITED

(A GOVERNMENT OF PUDUCHERRY UNDERTAKING)

PROJECT OFFICE, T.R. PATTINAM 609 606, KARAIKAL.

Phone: 04368-233060, 233344

Email: ppclmmc@gmail.com

Telefax: 04368-233355.

Ref.No: AC-014/MMC/2025-26/ **506**

GSTIN No.34AAACP6507E1ZS

Dt. **18** 06.2025

ENQUIRY PAGE NO. 2

Sl. No.	Description	Qty reqd. (in No's)	Total Amount (in Rs.)
Diaphragm Pressure Gauges for Raw Water and Cooling Water Chlorination system.			
1	Diaphragm Pressure Gauge Range: -1 to 1 Kg/cm ² Operating Pressure: 1Kg/cm ² Temperature: 65°C Medium: Chlorine As per the data sheet in the annexure.	04	
2	Diaphragm Pressure Gauge Range: 0 - 16 Kg/cm ² Operating Pressure: 10Kg/cm ² Temperature: 65°C Medium: Chlorine As per the data sheet in the annexure.	04	
Sub Total			
Add: Packing & Forwarding Charges @ %			
Add: Freight Charges @ %			
Add: GST @ %			
Total Amount			

Commercial Terms and Condition:

Sl. No	Details	Terms in Tender	Terms Accepted by the Party
1	Price Quoted	F.O.R. at Site, PPCL, Karaikal	
2	Payment Terms	As per the terms and condition Clause 4	
3	Validity	90 Days from date of opening of Tender	
4	Delivery Period	Vendor to specify	
5	Acceptance of All the Terms and Condition of the Enquiry	To be Accepted	

Signature with Seal of the Party



PUDUCHERRY POWER CORPORATION LIMITED

(A GOVERNMENT OF PUDUCHERRY UNDERTAKING)

PROJECT OFFICE, T.R. PATTINAM 609 606, KARAIKAL.

Phone: 04368-233060, 233344

Email: ppclmmc@gmail.com

Telefax: 04368-233355.

Ref.No: AC-014/MMC/2025-26/ 506

GSTIN No.34AAACP6507E1ZS

Dt. 18.06.2025

ENQUIRY PAGE NO. 4

DATA SHEET FOR DIAPHRAGM PRESSURE GAUGE		
Sl.No	Description	Details
1	Reference Standard	EN 837-3
2	Dial size	150 mm
3	Dial	Aluminum, white background with Black markings
4	Case & Bezel	SS304, Bayonet type bezel , Weatherproof to IP-67
5	Window	Toughened glass
6	Bourdon	SS 316L
7	Socket	SS 316L
8	Movement	SS 304
9	Mounting	Bottom Entry
10	Accuracy	+/- 1% FSD
11	Over range	130 % FSD
12	Pointer	Light weight micrometer pointer with black colour
13	Gasket & Filling plug	Provided
14	Blow out disc	Provided
15	Process temperature	65 °C
16	Diaphragm seal Screwed end	
17	Process Connection	½" NPT (M)
18	Top Chamber	Vendor to Specify
19	Diaphragm MOC	Tantalum