



PUDUCHERRY POWER CORPORATION LIMITED
(A GOVERNMENT OF PUDUCHERRY UNDERTAKING)

T.R. PATTINAM - 609606, KARAIKAL.

Phone No:04368- 233060

E-Mail : ppclmmc@gmail.com

Fax: 04368 - 233355.

Ref. No: AB-099 R/MMC/2025-26/1134

Our GSTIN No.: 34AAACP6507E1ZS

Dt. 23.09.2025

ENQUIRY

To

As per list enclosed

Sub: Inviting offer for the Supply of PTFE inner core Convolute
SS Wire Braided Hose for Gas Turbine Oil Centrifuge and
water wash skid - Reg.

QUOTATION TO BE:

Submitted on or before: 13.10.2025 - 12.00 Noon	Opened on: 14.10.2023 - 03.00 P.M.
Kept valid for 3 months from the date of opening	Submitted in One part.

Sealed quotations are invited for the Supply of PTFE inner core Convolute SS Wire Braided Hose for Gas Turbine Oil Centrifuge and water wash skid as per the Specification enclosed in the Annexure-II and as per the terms and conditions mentioned therein.

Terms and conditions:

1. The rate quoted should be firm and inclusive of all taxes and other charges as admissible.
2. The materials should be directly supplied to the PPCL site, T.R.Pattinam, Karaikal - 609 606, on door delivery basis.
3. Payment will be made within 30 days from the date of receipt of your invoice after receipt of materials in good condition. The bill in triplicate along with advance stamped receipt should be sent to the undersigned for effecting payment.
4. No payment will be made against document through bank.
5. Part payment will not be accepted for the supply of ordered items.
6. Order will be placed to the tenderer on item wise comparison of rate basis. All items to be quoted.
7. Bidder shall be a manufacturers (or) authorized Agents.
8. Bidder should provide test Certificate as per MIL Standard.
9. The delivery period and mode of despatch should be clearly specified.



PUDUCHERRY POWER CORPORATION LIMITED
(A GOVERNMENT OF PUDUCHERRY UNDERTAKING)

T.R. PATTINAM - 609606, KARAIKAL.

Phone No: 04368- 233060

E-Mail : ppclmmc@gmail.com

Fax: 04368 - 233355.



एक मंदम स्वच्छता की ओर


Our GSTIN No.: 34AAACP6507E1ZS

Dt. 23.09.2025

Ref. No: AB-099 R/MMC/2025-26/1134


Enquiry Page No.2

10. Validity: Your offer should be valid for 90 days from the date of receipt of your quotation.
11. Our GSTIN No.: 34AAACP6507E1ZS are registered with Commercial Taxes Department, Puducherry.
12. Any loss or damage during transit to site should be made good by the supplier free of charge provided the same is reported within 15 days of the arrival of material at site.
13. Sealed quotations should be super scribed as "QUOTATION/ENQUIRY NO. AB-099 R for the Supply of PTFE inner core Convolute SS Wire Braided Hose for Gas Turbine Oil Centrifuge and water Wash System", due on 3.10.2025.
14. If the tender opening date happens to be a holiday, the tender will be opened on the next working day.
15. Applicable taxes, freight and other charges should be clearly mentioned as whether inclusive or extra. If not mentioned, it will be presumed that the rate quoted is inclusive of all taxes and other charges.
16. The undersigned reserves all rights to accept/reject any or all the quotations without assigning any reasons thereof.


22/09/2025
EXECUTIVE ENGINEER (MECH) PLANT



PUDUCHERRY POWER CORPORATION LIMITED
(A GOVERNMENT OF PUDUCHERRY UNDERTAKING)
T.R. PATTINAM - 609606, KARAİKAL.



Phone No:04368- 233060

E-Mail : ppclmmc@gmail.com

Fax: 04368 - 233355.

Ref. No: AB-099 R/MMC/2025-26/1134

Our GSTIN No.: 34AAACP6507E1ZS

Dt. 23.09.2025

Dt. 23.0

Sl. No.	Item Description	Required Quantity		Rate Per Unit (in Rs.)	Total Value (in Rs.)
SS WIRE BRAIDED FLEXIBLE HOSE					
1.	25 mm ID Teflon (PTFE) inner core with outer SS wire Double braided flexible hose.	02	Nos		
2.	12.5 mm ID Teflon (PTFE) inner core with outer SS wire Double braided flexible hose	04	Nos		
(As per the Specification mentioned in Annexure-II)					
				Gross Total	
Packing and Forwarding charges in				% only	
Freight Charges in				% only	
				Sub Total	
				GST	%
				NET TOTAL	
(Rupees					
Terms and Condition:-					

Terms and Condition:-

SL No.	Details	Terms in Enquiry	Terms Accepted by the Party
01.	Price Quoted	Inclusive of all taxes & charges FOR Site	
02.	Payment Terms	As per Clause 3 of General Terms and conditions of our enquiring	
03.	Validity	90 Days from date of opening.	
04.	Delivery period	To be Specified	
06.	Test Certificate	Test Certificate to be provided. Clause 8	
07.	Acceptance of all our terms & conditions of our enquiry. (Specification mentioned in Annexure-II)	To be Accepted	

Name of the Company:

Company seal with Signature:



PUDUCHERRY POWER CORPORATION LIMITED
(A GOVERNMENT OF PUDUCHERRY UNDERTAKING)

T.R. PATTINAM - 609606, KARAIKAL.

Phone No:04368- 233060

E-Mail : ppclmmc@gmail.com

Fax: 04368 - 233355.

Ref. No: AB-099 R/MMC/2025-26/1134

Our GSTIN No.: 34AAACP6507E1ZS

Dt. 23.09.2025

ANNEXURE-II

Specification for Wire braided flexible hose:

SI No.	House ID	End fittings		Length	Operating	
		One end	Other end		Pressure	Temp
	mm	inch	inch	meter	Kg/cm ²	°C
01.	25 mm ID Teflon (PTFE) inner core with outer SS wire Double braided flexible hose.	1" BSP Swivel Hex SS nut female	1" Swivel SS Flange class 150 drilled	4	15	120
02.	12.5 mm ID Teflon (PTFE) inner core with outer SS wire Double braided flexible hose	1/2" BSP Gripped HEX Nipple	1/2" BSP Swivel Hex SS nut female	1	15	120

Note.

1. All hoses shall be made of Teflon (PTFE) Inner Core, reinforced with stainless steel SS 316 wire braiding.
2. All end fittings like hoses ends, stub ends shall be of 316/316L materials. Loose flanges shall be of 316 materials.
3. The house end fittings supplied shall be confirms to the specifications and they shall be attached to house by crimping.
4. All stub end and loose flanges shall confirm to ANSI B 16.5
5. All flexible hoses shall be manufactured in accordance with MIL standard (MIL-DTL-25579G)
6. Supplier has to submit the drawings and specify recommended minimum static and dynamic bend radius of hoses.
7. Number of Splicing /Joining of hoses to make up the full length shall not be allowed.

(Signature) 22/09/2024

EXECUTIVE ENGINEER (MECH) PLANT