



PUDUCHERRY POWER CORPORATION LIMITED (A GOVERNMENT OF PUDUCHERRY UNDERTAKING) T.R. PATTINAM - 609606, KARAIKAL.

Phone No:04368- 233060

E-Mail: ppclmmc@gmail.com

Our GSTIN No.: 34AAACP6507E1ZS

Dt/6.02.2023

Ref. No.W-122/MMC/2022-23/2300

DUE DATE EXTENSION

To (As per list enclosed)

Sub: Inviting offer for the Supply of Safety Valves for PRDS System-Reg.

Ref: Enquiry No.W-122/MMC/2022-23/2146, Dt.24.01.2023.

OUOTATION TO BE

QUOTIMIENT 10 11					
Submitted on or before: 06.03.2023 - 12.00 Noon	Opened on: 07.03.2023 - 3.00 PM				
Kept valid up to three months	Submitted in one part.				

Sealed quotations are invited for the Supply of Safety Valves for PRDS System as per the specification and details mentioned in the annexure and as per the terms and conditions mentioned therein.

General Terms & Conditions:

- 1. The rate quoted should be firm and inclusive of all taxes and other charges as admissible.
- 2. The materials should be original and specified make only.
- 3. The materials should be directly supplied to the PPCL site, T. R. Pattinam, Karaikal 609 606, on door delivery basis.
- 4. The bill in triplicate along with <u>advance stamped receipt</u> should be sent to the undersigned for effecting payment.
- 5. 100% payment will be made within 30 days from the date of receipt of your invoice after receipt of materials at site in good condition.
- No payment will be made against document through bank. Part payment will not be made for the supply of ordered item.
- 7. <u>Guarantee Certificate</u>: Guarantee certificate should be produced along with bill guaranteeing the materials supplied for the period of 18 months (Eighteen months) from the date of receipt at site for satisfactory operation and good workmanship or 12 months from the date of commissioning whichever is earlier.
- 8. Order will be placed to the tenderer for which the tenderer had quoted the least rate of total amount. The bidder has to quote the amount inclusive of all charges and taxes.
- 9. Valves to be supplied only after obtaining drawing approval from PPCL.
- 10. Test Certificate to be produced along with Supply.





PUDUCHERRY POWER CORPORATION LIMITED (A GOVERNMENT OF PUDUCHERRY UNDERTAKING) T.R. PATTINAM - 609606, KARAIKAL.

Phone No:04368- 233060

E-Mail: ppclmmc@gmail.com

Our GSTIN No.: 34AAACP6507E1ZS

Dt# .02.2023

Ref. No.W-122/MMC/2022-23/ 2500

ENQUIRY Page No.2

- 11. The delivery period and mode of despatch should be clearly specified.
- 12. Validity: Your offer should be valid for 90 days from the date of tender opening.
- 13. Our GSTIN No.: 34AAACP6507E1ZS are registered with Commercial Taxes Department, Puducherry.
- 14. Any loss or damage during transit to site should be made good by the supplier free of charge provided the same is reported within 15 days of the arrival of material at site.
- 15. Liquidity Damage Clause: If the contractor fails to complete the work as scheduled after placing the work order, then the Contractor shall pay LD @ 0.5% for each week delay in work and the total LD % will be subject to the maximum of 5% of the total value.
- Wax sealed quotations should be super scribed as "QUOTATION/ENQUIRY NO. W-122 for the Supply of Safety Valves for PRDS System due on 06.03.2023.
- 17. If the tender opening date happens to be a holiday, the tender will be opened on the next working day.
- 18. Applicable taxes, freight and other charges should be clearly mentioned as whether inclusive or extra. If not mentioned, it will be presumed that the rate quoted is inclusive of all taxes and other charges.
- 19. The undersigned reserves all rights to accept/reject any or all the quotations without assigning any reasons thereof.

20. Please note the date of opening, if the offer has already been submitted.

EXECUTIVE ENGINEER (MECH)-PLANT





PUDUCHERRY POWER CORPORATION LIMITED (A GOVERNMENT OF PUDUCHERRY UNDERTAKING) T.R. PATTINAM - 609606, KARAIKAL.

Phone No:04368- 233060

E-Mail: ppclmmc@gmail.com

Our GSTIN No.: 34AAACP6507E1ZS

Ref. No.W-122/MMC/2022-23/ 2300

Dt./6.02.2023

Annexure Page No.1

Sl.	Description / Specification	Make	Qty.	Unit Rate	Total			
No.					Amount in ₹			
1.	SAFETY VALVE	Reputed	01 No					
Specifications as per Annexure Page-2								
	Sub-Total							
	P & F Charges in % only							
		Freight Charges in % only						
(Rup	(Rupees							

Delivery Period:

Payment Terms: 30 days after receipt of material

Validity: 90 Days from the date of opening the tender.

Note: 1) The rates to be quoted in all the columns of the above schedule and no columns should be left blank.

2) The quoted schedule should be affixed by the company seal and signed by the concerned authority for the bidder.

Name of the Company:

Company seal with signature:





Phone No:04368- 233060

E-Mail: ppclmmc@gmail.com

Our GSTIN No.: 34AAACP6507E1ZS

Ref. No.W-122/MMC/2022-23/ 2300

Dt/6.02.2023

ANNEXURE Page No.2

SAFETY VALVES FOR PRDS SYSTEM

PRDS SAFETY VALVE SPECIFICATION DETAILS:

MATERIAL DATA

Body : ASTM A2 16 Gr WCB

Cap. : Carbon Steel

Disc : SS410

Disc Holder : SS410

Spindle : SS410

Gasket : Non-asbestos

Other Internals : SS410

Fasteners : ASTM A216Gr WCB

Spring : Spring Steel

Bonnet : ASTM A216Gr WCB

Nozzle : SS410

PROCESS DATA

Type : Spring loaded safety valve

Lever : Required Service : Steam

Operating pressure : 10.5 Kg/ Cm²
Operating temperature : 350 degC
Set Pressure : 12 Kg/ Cm²

Inlet connection size : 40NB Out let connection size : 50 NB

Inlet connection : ANSI B 16.5ASA 150 # RF
Oulet connection : ANSI B 16.5ASA 150 # RF

❖ Test Certificate to be produced along with supply

Safety Valve to be supplied along with IBR test Certificate.

Materials/Valves to be supplied only after the drawing approval from PPCL.