



PUDUCHERRY POWER CORPORATION LIMITED

(A GOVERNMENT OF PUDUCHERRY UNDERTAKING)

PROJECT OFFICE, T.R. PATTINAM 609 606, KARAIKAL.

Phone: 04368-233060

Email: ppclmmc@gmail.com

Telefax: 04368-233355.

Ref.No: AC-018/MMC/2025-26/ **507**

GSTIN No.34AAACP6507E1ZS

Dt. **18**06.2025

ENQUIRY

To

Sub: Inviting offer for the Procurement of Temperature Gauges – Reg.,

QUOTATION TO BE:

Submitted on or before – 10.07.2025 –5 pm	Opened on 11.07.2025 - 3.00 P M
Kept valid for 3 months from the date of opening	Submitted in ONE part.

Sealed quotations are invited for the supply of Temperature Gauges As per the Specifications & data sheet and as per the terms and conditions mentioned therein.

Terms and conditions:

1. The rate quoted should be firm and inclusive of all GST and other charges as admissible.
2. Applicable other charges, if any should be clearly mentioned. If not mentioned, it will be presumed that the rate quoted is inclusive of all other charges.
3. The materials should be original, specified make only.
4. The materials should be directly supplied to the PPCL site, T. R. Pattinam, Karaikal - 609 606, on door delivery basis.
5. **Payment:** 100% Payment will be made within 30 days from the date of receipt of your invoice after receipt of materials in good condition. The **bill in triplicate** along with **Advance stamp fixed and signed receipt** should be sent to the undersigned for effecting payment. Part payment will not be made for the supplied items.
6. The delivery period and mode of dispatch should be clearly specified.
7. Any loss or damage during transit to site should be made good by the supplier free of charge provided the same is reported within 15 days of the arrival of material at site.
8. **Validity:** Your offer should be valid for 90 days from the date of tender opening.
9. **The L1 bidder shall be arrived as the lowest bidder for each item.**
10. Sealed quotations should be superscripted as "QUOTATION/ENQUIRY NO. AC-018 for the supply of Temperature Gauges".
11. Quotations through fax /e-mail not accepted.
12. If the tender opening date happens to be a holiday, the tender will be opened on the next working day.
13. Our **GSTIN No.34AAACP6507E1ZS** is registered with Commercial Taxes Department, Puducherry. The GST number of the agency should be provided.
14. The undersigned reserves all rights to accept/reject any or all the quotations without assigning any reasons thereof.

(Signature)

18/06/2025

EXECUTIVE ENGINEER (MECH)-PLANT

Page 1 of 4



PUDUCHERRY POWER CORPORATION LIMITED



(A GOVERNMENT OF PUDUCHERRY UNDERTAKING)

PROJECT OFFICE, T.R. PATTINAM 609 606, KARAIKAL.

Phone: 04368-233060

Email: ppclmmc@gmail.com

Telefax: 04368-233355.

Ref.No: AC-018/MMC/2025-26/507

GSTIN No.34AAACP6507E1ZS

Dt. 18.06.2025

ENQUIRY PAGE NO. 2

Sl. No	Area	Range (°C)	Medium	Operating parameters Pressure (Kg/Cm2)/ Temperature (°C)	Dial Size (mm)	Inst Connection	Qty Reqd No's	Unit Rate (In Rs)	Total Amount (Rs.)
DIRECT MOUNT TYPE TEMPERATURE GAUGE									
1	Cooling Water System	0-100 °C	Water	5(Kg/Cm2)/ 50°C	150	½" NPT(M)	05		
CAPILLARY MOUNT TYPE TEMPERATURE GAUGE									
2	Cooling Water System	0-100 °C	Gas	21(Kg/Cm2)/ 125°C	150	½" NPT(M)	20		
3	Condensate	0-200 °C	Gas	45(Kg/Cm2)/ 125°C	150	½" NPT(M)	10		
Add: P&F Charges @ %									
Add: Freight Charges @ %									
Add: GST @ %									
Total Amount.									

Commercial terms and Conditions:

Sl.No	Details	Terms in Tender	Terms Accepted by the Party
1	Price Quoted	FOR Site	
2	Payment Terms	As per the terms and condition	
3	Validity	90 Days from date of opening of Tender	
4	Delivery	Vendor to specify	
5	Acceptance of All the Terms and Condition of Enquiry	To be Accepted	

Signature with Seal of the Party



PUDUCHERRY POWER CORPORATION LIMITED

(A GOVERNMENT OF PUDUCHERRY UNDERTAKING)

PROJECT OFFICE, T.R. PATTINAM 609 606, KARAIKAL.

Phone: 04368-233060

Email: ppclmmc@gmail.com

Telefax: 04368-233355.

Ref.No: AC-018/MMC/2025-26/507

GSTIN No.34AAACP6507E1ZS

Dt. 18.06.2025

ENQUIRY PAGE NO. 3

DATA SHEET FOR DIRECT MOUNT TEMPERATURE GAUGE		
Sl.no	Description	Details
1	Type	Mercury/Inert Gas in steel with case compensation
2	Mounting	Bottom Entry and Direct Mount Type with all accessories provided by the vendor.
3	Dial Diameter	150 mm
4	Case	Die cast Aluminum
5	Ring	Vendor to Specify
6	Blow-out Protection	Disc
7	Lens	Shatter Proof Glass
8	Nominal Accuracy	within 1% of Range
9	Dial Colour	WHITE With BLACK NUMERAL
10	Over Range Protection	130 % of FSD
11	Zero Adjustment	Required
12	Scale	°C
13	Press. Element	SS 316
14	Element Mtl	SS 316
15	Socket Mtl	SS
16	Connection-NPT	1/2 in. NPT M
17	Connection	Vendor to Specify
18	Movement	SS 316
19	Pointer Mtl:	BLACK ALUMINIUM
20	Enclosure Class	IP 65
21	MFR & model	Reputed
22	Stem/Bulb	8 mm OD in SS316, Length 450mm



PUDUCHERRY POWER CORPORATION LIMITED

(A GOVERNMENT OF PUDUCHERRY UNDERTAKING)

PROJECT OFFICE, T.R. PATTINAM 609 606, KARAIKAL.

Phone: 04368-233060

Email: ppclmmc@gmail.com

Telefax: 04368-233355.

Ref.No: AC-018/MMC/2025-26/ **507**

GSTIN No.34AAACP6507E1ZS

Dt. **18**.06.2025

ENQUIRY PAGE NO. 4

DATA SHEET FOR CAPILLARY MOUNT TYPE TEMPERATURE GAUGE

Sl.No	Description	Details
1	Type	Mercury/Inert Gas in steel with case compensation
2	Mounting	Back entry/Flush Panel Mounting for capillary type With all accessories provided by the vendor
3	Dial Diameter	150 mm
4	Case	Die cast Aluminum
5	Ring	Vendor to Specify
6	Blow-out Protection	Disc
7	Lens	Shatter Proof Glass
8	Nominal Accuracy	within 1% of Range
9	Dial Colour	WHITE With BLACK NUMERAL
10	Over Range Protection	130 % of FSD
11	Zero Adjustment	Required
12	Scale	° C
13	Press. Element	SS 316
14	Element Mtl	SS 316
15	Socket Mtl	SS
16	Connection-NPT	1/2 in. NPT M
17	Connection	Vendor to Specify
18	Movement	SS 316
19	Pointer Mtl:	BLACK ALUMINIUM
20	Enclosure Class	IP 65
21	MFR & model	Reputed
22	Capillary Material	SS Covered and Armoured Capillary, Length 6 Mtrs.
23	Stem/Bulb	8 mm OD in SS316, Length 450mm