



PUDUCHERRY POWER CORPORATION LIMITED

(A GOVERNMENT OF PUDUCHERRY UNDERTAKING)

PROJECT OFFICE, T.R. PATTINAM 609 606, KARAIKAL.

Phone: 04368-233060

Email: ppclmmc@gmail.com

Telefax: 04368-233287

Ref.No.AC-062/MMC/2025-26/939

GSTIN No.34AAACP6507E1ZS

Dt.21.08.2025

ENQUIRY-DUE DATE EXTENSION

TO

Sub: Inviting offer for Rewinding and Servicing of Raw Water Pump-1 Motor- Reg.

Ref: Our Enquiry ref no: AC-062/MMC/2025-26/712 Dated: 19.07.2025.

QUOTATION TO BE:

Submitted on or before: 26.08.2025 -5.00 pm	Opened on: 28.08.2025 - 03.00 pm
Kept valid for 3 months from the date of opening	Submitted in TWO parts.

Sealed quotation is invited for **Rewinding and Servicing of Raw Water Pump-1 Motor at Contractors works site. The scope of work and specification of raw water pump motor** are enclosed and the terms & conditions are mentioned therein.

The Party should have successfully completed servicing/rewinding of motors of capacity 30KW or above during the past three years. Supporting documents are to be submitted with the offer.

General Terms and conditions:

1. The rate quoted should be inclusive of manpower, boarding & lodging, local conveyance transport charges, tools and tackles, etc. required for the works, all taxes and other charges as admissible.
2. Applicable other charges, if any should be clearly mentioned as whether inclusive or extra. If not mentioned, it will be presumed that the rate quoted is inclusive of all other charges.
3. The rate has to be quoted in the prescribed tabular column format for work measurement. **The work should be carried out at contractor's work site.**
4. The rewinding and servicing works of motor has to be carried out as per the scope of works. **The specification of the Raw water pump motor and the scope of the work are enclosed.**
5. In case of any faulty workmanship in the scope of work, the tenderer must rectify the same on free of Cost.
6. **PAYMENT: 100%** Payment for Overhauling Work will be made within 30 days from the date of receipt of your invoice after completion of work satisfactorily and approval of Engineer-in-charge.
7. Our Tax payment Identification **GSTIN No.34AAACP6507E1ZS** is registered with Commercial Taxes Department, Puducherry. Bidder should furnish their GST details.
8. Quotations through fax/mail and received after due date will not be considered.
9. Sealed quotations should be superscripted as "QUOTATION/ENQUIRY NO.AC-062 for rewinding and servicing of raw water pump motor".
10. The undersigned reserves all rights to accept/reject any or all the quotations without assigning any reasons thereof.
11. The work order is not transferable and subcontract/sublet of work is not permitted.
12. ***If already submitted the offer earlier for the enquiry reference cited above, please make a note of the due date extension.***

EXECUTIVE ENGINEER (MECH.)-PLANT

Page 1 of 3

ENQUIRY PAGE-2**SCOPE OF WORK FOR REWINDING OF RAW WATER PUMP MOTOR**

1. The motor to be taken from site for rewinding & repairing.
2. Rewinding to be carried out with new copper coils in all three phases and with F class insulation.
3. New bearings SKF 6212 C3 to be replaced both DE and NDE side. The test and warranty certificates for the bearings are to be produced.
4. Any machining cost that may be required in motor servicing to be done in contractor scope
5. The terminal block / insulators of the motor if found damaged to be replaced.
6. Motor space heater if found not working to be replaced.
7. IF the cooling fan of the motor found in damaged condition it should be replaced under contractor's scope.
8. All spares and consumables required for rewinding and servicing of the motor is under contractor's scope.
9. Necessary routine tests, Insulation test, winding resistance, no load test on the motor to be carried out and report submitted.
10. The contractor should provided performance and service guarantee for the period of minimum six months.
11. Two coats of Painting (Smoke Grey Color) of the motor to be carried out.
12. The motor after completion of servicing to be delivered at site.
13. If any abnormal sound /overheating/abnormal current observed at no load and full load condition it has to be rectified by the contractor at their own cost for smooth operation.
14. In case of any faulty workmanship in the above scope of work, the party must rectify the same at their own cost.

Specifications of Raw water pump motor

Make: BBL 3 Ph Induction motor

Machine No: M9901021, Type: 1LA 3202-2,

KW/HP: 30/40, Frame: 200L, Insulation class & Duty: F/S1,

Voltage & Current: 415V/ 52.5 A Delta Connected, Frequency: 50 HZ,

RPM: 2955, Efficiency: 91%, IP55,

Bearings: DE/NDE: 6212C3 /6212C3.



PUDUCHERRY POWER CORPORATION LIMITED

(A GOVERNMENT OF PUDUCHERRY UNDERTAKING)

PROJECT OFFICE, T.R. PATTINAM 609 606, KARAIKAL.

Phone: 04368-233060

Email: ppclmmc@gmail.com

Telefax: 04368-233287

Ref.No.AC-062/MMC/2025-26/939

GSTIN No.34AAACP6507E1ZS

Dt. 21.08.2025

ENQUIRY PAGE-3

Sl. No	Description/Specifications	Qty	Rate per unit (Rs.)	Amount (Rs.)
1	Charges for the Repair and rewinding of raw water pump motor with new copper coils in all three phases with F class insulation including varnishing. Drying, painting, and less old copper scrap. As per the scope of works enclosed.	01 No		
2	Charges for the supply & replacement of bearings: DE/NDE: 6212C3 /6212C3	01 Set		
3	Transportation charges for the shifting of motor	Lumpsum		
Sub-Total				
GST @ %				
Total Amount (Rs.)				

Commercial Terms and Condition:

Sl.No	Details	Terms in Tender	Terms Accepted by the Party
1	Price Quoted	Inclusive of Material, manpower, tools & tackles transport charges, GST and other charges.	
2	Payment Terms	100% within 30 days from the date of completion of works satisfactory.	
3	Validity	90 Days from date of opening of Tender	
4	Supporting Documents for the previous experience	Should be enclosed	
5	Delivery/ Completion Period	Vendor to specify	
6	Acceptance of All the Terms and Condition of the Enquiry	To be Accepted	

Signature with Seal of the Party